



KEY:

- Existing Lighting Column (not numbered)
- Existing Lighting Column (LBM numbered)
- Proposed New LED Luminaire on 4m column
- Proposed New 1m LED Light Bollard
- Existing Tree
- Existing Tree of Moderate Ecological Value
- Existing Tree of High Ecological Value
- Existing Underground Drainage
- Existing Underground Electricity Cables
- Curtilage of Path to be Illuminated



<p>STUDIO DEKKA LIMITED SHALL HAVE NO RESPONSIBILITY FOR ANY USE MADE OF THIS DOCUMENT OTHER THAN FOR THAT WHICH IT WAS PREPARED AND ISSUED.</p> <p>ALL DIMENSIONS SHOULD BE CHECKED ON SITE. DO NOT SCALE FROM THIS DRAWING.</p> <p>ANY DRAWING ERRORS OR DIVERGENCES SHOULD BE BROUGHT TO THE ATTENTION OF STUDIO DEKKA LIMITED AT THE ADDRESS SHOWN.</p>	<p>#478826 / 02824075-02</p> <p>Technical Design - First Issue</p> <p>Author: JH</p> <p>Check: CS</p> <p>Date: 31/10/16</p>	<p>TO BE READ IN CONJUNCTION WITH:</p> <p>Drawings: DWG E(63) 804 to 815 - Proposed Lighting Layout - Areas 1 to 12</p> <p>SCH E(63) 901 - Schedule of Luminaires</p> <p>SPC E(63) 601 - Lighting Specification</p>	<p>Before commencing any works on site (including trial holes) the contractor should observe UNPN, Thames Water and Virgin Media drawings issued by London Borough of Merton on 18th and 19th of July 2016 for details and locations of all underground services.</p> <p>All efforts have been taken to re-use as many existing columns as possible as well as locate luminaire positions away from underground services such including extra high voltage and high voltage cables and waste water pipes.</p> <p>A list of positions of trial holes is noted in the lighting specification.</p> <p>All efforts have been taken to locate luminaires away from trees and features of high and moderate ecological value.</p>	<p>PROJECT TITLE: Wandle Trail - Amenity Lighting for Proposed Quietway</p> <p>CLIENT: Sustrans for the London Borough of Merton</p> <p>PROJECT NUMBER: Proposed Lighting Layout Area 5</p>	<p>PROJECT NO: E(63) 808</p> <p>PROJECT NO: 1124</p> <p>SCALE: 1:100 @A3</p> <p>DATE: 31/10/2016</p> <p>PROJECT NO: -</p> <p>STUDIO DEKKA Independent Lighting Design Consultants</p> <p>3 The School House 1a West Park Street, DUNSBURY WY13 4DA</p> <p>+44 (0) 1924 451 486 studio@studiodekka.com www.studiodekka.com</p>
---	---	---	---	---	--